

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Bruce Dalton ADDRESS Clover Valley

2. LOCATION 1/4 1/4 Sec. 25 T. 36 N/S R. 61 E. ER County
 PERMIT NO.

3. TYPE OF WORK		4. PROPOSED USE			5. TYPE WELL	
New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Test <input type="checkbox"/>	Cable <input type="checkbox"/>	Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/>	Other <input type="checkbox"/>	Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>	Other <input type="checkbox"/>	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		0	1	
Boulders		1	17	
GRAVEL & Sand	X	17	30	
Brown Clay		30	67	
TEA Kettle Limestone		67	69	
Brown Clay		69	77	
GRAVEL & sand	X	77	125	
Decomposed granite gravel		125	180	
granite Boulders		180	210	

6 GPM @ 125'

8. WELL CONSTRUCTION

Diameter hole 10 inches Total depth 125 feet
 Casing record
 Weight per foot 5" 250 Thickness 198

Diameter	From	To
<u>6</u> inches	<u>1</u> feet	<u>125</u> feet
<u>5</u> inches	<u>9.5</u> feet	<u>152</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type Concrete
 Depth of seal 5.5 feet
 Gravel packed: Yes No
 Gravel packed from 5.5 feet to 125 feet

Perforations:
 Type perforation Mills Knife
 Size perforation 1/2" x 3"
 From 5.5 feet to 125 feet
 From feet to feet

Date started Dec 17, 1980
 Date completed Dec 29, 1980

9. WATER LEVEL

Static water level 2059 Feet below land surface 2059
 Flow G.P.M.
 Water temperature COOL ° F. Quality good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name R.P. Reynolds
 Address Wells Road
 Nevada contractor's license number 21840
 Nevada driller's license number 76
 Signed [Signature]
 Date 1-1-81

BAILER TEST

G.P.M. <u>157</u>	Draw down <u>30</u> feet	<u>2</u> hours
G.P.M.	Draw down feet hours
G.P.M.	Draw down feet hours