

WELL DRILLERS REPORT

Please complete this form in its entirety



1. OWNER RAY LAGARZA ADDRESS W. WASHINGTON
Block 13 Lot 9
 2. LOCATION SW 1/4 50 1/4 Sec. 22 T. 34 N. R. 37 E. Humboldt County
 PERMIT NO. _____

3. TYPE OF WORK		4. PROPOSED USE		5. TYPE WELL	
New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Cable <input type="checkbox"/>	Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/>	Other <input type="checkbox"/>	Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	5	
clay		5	25	
SANDY clay		25	45	
gravel small		45	48	
clay		48	87	
gravel		87	92	
clay		92	96	
gravel		96	145	

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 145 feet
 Casing record _____
 Weight per foot _____ Thickness 1.0 g/a
 Diameter 6 inches From 0 feet To 145 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 52 feet
 Gravel packed: Yes No
 Gravel packed from 52 feet to 145 feet
 Perforations:
 Type perforation S.D.W.
 Size perforation 1/2" x 3/16" S.W.S.
 From 86 feet to 100 feet
 From _____ feet to _____ feet

Date started 10-17-79, 19____
 Date completed 10-17-79, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 55 Feet below land surface
 Flow _____ G.P.M.
 Water temperature 62.5 ° F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GARY W. SCHULTZ
 Address Box 647
 Nevada contractor's license number 121102
 Nevada driller's license number 601
 Signed Gary W. Schultz
 Date 10-17-79