



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER RE Sievert ADDRESS Wadsworth - 31499 Interstate 905110

2. LOCATION NE 1/4 NE 1/4 Sec. 8 T. 20 S. R. 23 E. Washoe County  
 PERMIT NO.

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	4	
Brown sand		4	18	
gravel and sand		18	94	
hard blue rock fractured		94	195	
red rock - medium hard		195	198	
Blue sandy clay		198	388	
Blue rock and layers of clay		388	465	
Blue and black rock medium hard - some stringers of clay		465	500	
T.D. 500' no H <sub>2</sub> O at this point				
Dick Sievert stopped driller				

8. 10" - 50" WELL CONSTRUCTION

Diameter hole 8 1/2 inches Total depth 500 feet  
 Casing record.....  
 Weight per foot 10.77 Thickness 1.00  

Diameter	From	To
<u>6 1/2</u> inches	<u>12</u> feet	<u>95</u> feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

 Surface seal: Yes  No  Type.....  
 Depth of seal..... feet  
 Gravel packed: Yes  No   
 Gravel packed from..... feet to..... feet  
 Perforations:  
 Type perforation None  
 Size perforation.....  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

9. WATER LEVEL

Static water level None Feet below land surface.....  
 Flow..... G.P.M.  
 Water temperature..... ° F. Quality.....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service  
 Address Sparks Nevada  
 Nevada contractor's license number 15291  
 Nevada driller's license number 817  
 Signed Frank Padilla  
 Date 9-9-81

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. .... Draw down..... feet ..... hours  
 G.P.M. .... Draw down..... feet ..... hours  
 G.P.M. .... Draw down..... feet ..... hours