WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 23844
Permit No.
Basin

1. OWNER LABE INVESTMENT/LEON SCHNEIDER ADDRESS 3285 Clover Way #318, Reno Nevada 89509

2. LOCATION NW ¼ SW ¼ Sec. 16 T. 21N N/S R. 18 E. Washoe County
Cold Springs
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	20	19
Green clay		20	27	7
Brown clay		27	52	25
Brown sand & gravels		52	65	13
Coarse sand & gravels	x	65	89	24
Brown clay		89	90	1
Water Strata (68-89)				

Date started 6-24-82, 19
Date completed 6-24-82, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 x 6 inches Total depth 90 feet
Casing record 90
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	90 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 51 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 51 feet to 90 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2½ x 6 around
From 69 feet to 87 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 31 Feet below land surface
Flow 30 G.P.M. with air
Water temperature cold °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc.
Address P.O. Box 12370, Reno Nevada 89510
Nevada contractor's license number 14043
Nevada driller's license number 923
Signed Edward Mondragon
Date June 25, 1982

USE ADDITIONAL SHEETS IF NECESSARY

O-627