

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Keith Bartelheim ADDRESS AT WELL LOCATION Pleasant View Drive  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NW 1/4 1/4 Sec. 1 T. 19 S. R. 20 E Washoe County  
 PERMIT NO. \_\_\_\_\_ Sunset View Rancho Estates Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	4	
Brown Clay		4	62	
Red Clay		62	162	
Red & Brown Clay		162	180	
Blue Clay and rock		180	238	
green Clay & rock		238	259	
Brown Clay & rock		259	269	
Brown Clay Black rock		269	312	
Black rock Broken		312	362	
med hard rock		362	390	

8. <sup>10 to 100'</sup> WELL CONSTRUCTION

Diameter hole 8 3/4 inches Total depth 385 feet  
 Casing record 6 3/8  
 Weight per foot \_\_\_\_\_ Thickness \_\_\_\_\_  
 Diameter \_\_\_\_\_ inches From \_\_\_\_\_ feet To 385 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Concrete  
 Depth of seal 100 feet  
 Gravel packed: Yes  No   
 Gravel packed from 385 feet to 110 feet  
 Perforations:  
 Type perforation factory mill  
 Size perforation 3x32x3  
 From 365 feet to 325 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 260 feet below land surface  
 Flow dry G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature cold ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AQUA DRILLING & Well Service Contractor  
 Address 2255 Glendale ave Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 817# Actual Driller  
 Signed Aqua Drilling Contractor Ruthner  
 Date 9-7-82

Date started 8-11, 1982  
 Date completed 9-2, 1982

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew well with 250 psi</u>			
<u>600 rpm for 5 hr</u>			

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours