WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 94449
Permit No.
Basin

NOTICE OF INTENT NO. 0596

1. OWNER CRAIG & SUSAN STADLER
MAILING ADDRESS 425 MORAN STREET
RENO, NV 89502

ADDRESS AT WELL LOCATION 3465 KINNEY LANE
RENO, NV

2. LOCATION NE ¼ SE ¼ Sec. 2 T 18 N/S R 19 E WASHOE County
PERMIT NO. (Issued by Water Resources) APN 21-120-21 (Parcel No.) (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy clay		0	3	3
gravel, cobblestones & boulders		3	7	4
sand & clay		7	12	5
sand, gravel & cobblestones	xx	12	27	15
coarse sand & gravel w/streaks brown clay		27	67	40
yellow clay w/some sand & gravel		67	80	13
fine to coarse sands & gravels	xx	80	127	47
brown clays w/sands & gravels		127	164	37
coarse sand, cobblestones w/streaks of brown clay	xx	164	195	31
decomposed granite w/fractures	xx	195	210	15

Date started February 8, 19 83
Date completed February 14, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3 horsepower	25	136	4

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 210 feet
Casing record 8 5/8" od x .188 wall
Weight per foot 16.94 Thickness

Diameter	From	To
8 inches	+1 feet	210 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement groout
Depth of seal 63 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 63 feet to 210 feet

Perforations:
Type perforation Milled
Size perforation 1/8" x 3"
From 167 feet to 210 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Flow 3 G.P.M. P.S.I.
Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SAGE BROS DRILLING COMPANY, INC. (Contractor)
Address 7800 N. VIRGINIA STREET RENO, NV 89506 (Contractor)
Nevada contractor's license number 7462A
Nevada contractor's drillers number ~~765~~ 774 Harold Sage
Nevada driller's license number 765 Bud Sage (Actual Driller)
Signed [signature] (Contractor)
Date FEBRUARY 21, 1983

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434