

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 2337

1. OWNER NEVADA BELL ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. BOX 11010 I-80 and INDEPENDENCE AVE.
RENO, NV. 89520
 2. LOCATION NE 1/4 NE 1/4 Sec. 16 T 19 N/S R. 21 E WASHOE County
 PERMIT NO. 45988
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Commercial Industrial Stock
 Municipal Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|------|-----|------------|
| Over burden | | 0 | 3 | 3 |
| Metamorphic rock, fractured black-white-green-blue-yellow. | | 3 | 23 | 20 |
| Hard black rock | | 23 | 27 | 4 |
| Volcanic rock, red-yellow-red | | 27 | 62 | 35 |
| Hard black rock | | 62 | 73 | 11 |
| Softer yellow-red-white rock | | 73 | 117 | 44 |
| Hard black rock | | 117 | 122 | 5 |
| Softer Volcanic formation--mixed with green shale-type rock, with some stringers of hard layers - fractured. | | 122 | 178 | 5 |
| T. D. - 178 ft. | | | | |

Plugged by Well Log # 115178

Date started 4-1, 1983
 Date completed 4-4, 1983

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|--|--------|-----------|------------------|
| Blew well for 2 hours to clean and develop - using 250 lbs. air at 600 cfm | | | |
| | | | |

BAILER TEST

| | | | |
|--------|-----------|------|-------|
| G.P.M. | Draw down | feet | hours |
| G.P.M. | Draw down | feet | hours |
| G.P.M. | Draw down | feet | hours |

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 160 feet
 Casing record 6 5/8 - .156
 Weight per foot 10.78 Thickness .156

| Diameter | From | To |
|---------------------|-----------------|-----------------|
| <u>6 5/8</u> inches | <u>18"</u> feet | <u>160</u> feet |
| | | |
| | | |
| | | |
| | | |
| | | |

Surface seal: Yes No Type Concrete
 Depth of seal 55 ft. feet
 Gravel packed: Yes No
 Gravel packed from 55 feet to 160 feet

Perforations:
 Type perforation Factory
 Size perforation 3/32 X 3
 From 143 feet to 160 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 94 feet below land surface
 Flow 12 G.P.M. P.S.I.
 Water temperature cool ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AQUA DRILLING & WELL SERVICE, INC.
 Address 2255 GLENDALE AVE. SPARKS, NV. 89431
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
 Signed Roger M. Thrall Actual Driller
 Date 4-4-83 copy in PER FILE