

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

Also # 24621  
 OFFICE USE ONLY  
 Log No. 24619  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Royal Surratt & Steve May ADDRESS Wendover Utah

2. LOCATION W 1/4 SW 1/4 Sec 3 T 36 N/S R 29 E Elk County \_\_\_\_\_  
 PERMIT NO. net 7

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravelly Soil		0	2	
Loose Gravel		2	32	
1" gravel		32	39	
Coarse Gravel		39	55	
Quartz Boulders	X	55	65	
1" gravel	X	65	67	
Coarse gravel 3"	X	67	73	
Quartz Boulders		73		

8. WELL CONSTRUCTION

Diameter hole 10 inches Total depth 74 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 188

Diameter	From	To
<u>10</u> inches	<u>11</u> feet	<u>74</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 74 feet

Perforations:  
 Type perforation Factory drilled  
 Size perforation 1/8" x 3"  
 From 57 feet to 74 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 53 Feet below land surface 53  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature 68 ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name RD Reynolds  
 Address Wells, Nevada  
 Nevada contractor's license number 01440  
 Nevada driller's license number 2461  
 Signed [Signature]  
 Date 5/11/83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAHNER TEST

G.P.M. 15 Draw down 10 feet 4 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

DEEPENED BY WG 124751