

OFFICE USE ONLY  
Log No. 25059  
Permit No. DOMESTIC  
Basin TR. MEADOWS 6-89

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 26114

PRINT OR TYPE ONLY

1. OWNER Bob Carabine ADDRESS AT WELL LOCATION Same  
MAILING ADDRESS 1845 Mazzanite Cir  
Reno, NV  
2. LOCATION N/E 1/4 NW 1/4 Sec 26 T 19N N/S R. 19 E Washoe County  
PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other   
4. PROPOSED USE Hot water  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock   
5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Yellow Sandy Clay	X	0	110	110
Blue Sandy Clay		110	372	262
Hard blue Clay		372	385	13
Hard Blue Shale		385	610	25
Blue Sandy Clay		610	616	6
Hard Blue Shale	X	616	660	44

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 660 feet  
Casing record 0-660  
Weight per foot \_\_\_\_\_ Thickness 172  
Diameter From To  
12 inches 0 feet 100 feet  
8 inches 100 feet 660 feet  
\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
Surface seal: Yes  No  Type Cement  
Depth of seal 0-100 feet  
Gravel packed: Yes  No   
Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Perforations:  
Type perforation Saw Slot  
Size perforation 3 2 1/2 x 3/32  
From 636 feet to 660 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 60 feet below land surface  
Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 70.3 F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Mackay Drilling  
Contractor  
Address 630 Starlite Cir  
Contractor  
Nevada contractor's license number 14170  
Nevada contractor's drillers number 514  
Nevada driller's license number 1226  
Actual Driller  
Signed Mitch Miller  
Contractor  
Date 12-11-83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>5-6</u>	<u>65</u>	<u>2</u>

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours