

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2669

1. OWNER ROGER PUCCINELLI ADDRESS AT WELL LOCATION  
 MAILING ADDRESS 516 ABBY WAY 345 LAKEVIEW DRIVE  
SPARKS, NV. 89431 VERDI  
 2. LOCATION SE 1/4 SE 1/4 Sec. 7 T 19 R/S R. 18 E WASHOE County  
 PERMIT NO. 38-042-26  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
OVERBURDEN		0	1	1
FRACTURED ROCK, GRAY WITH SOME CLAY--BROWN		1	26	25
LAYER OF LIGNITE MIXED WITH BROWN CLAY & SAND	XX	26	127	101
BLUE CLAY WITH HARD BOULDERS		127	129	2
T.D. 129 ft.				

8. WELL CONSTRUCTION  
 Diameter hole 10" for 56' 8 inches Total depth 129 feet  
 Casing record 6 5/8 inches Thickness .156  
 Weight per foot 10.78  
 Diameter 6 5/8 inches From 18 feet To 129 feet  
 Surface seal: Yes  No  Type GROUT  
 Depth of seal 56 feet  
 Gravel packed: Yes  No   
 Gravel packed from 56 feet to 129 feet  
 Perforations:  
 Type perforation Factory  
 Size perforation 3/32 X 3  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 109 feet to 129 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 36 feet below land surface  
 Flow 20+ G.P.M. P.S.I.  
 Water temperature COOL ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AQUA DRILLING & WELL SERVICE  
 Contractor  
 Address 2255 GLENDALE - SPARKS, NV. 89431  
 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132  
 Actual Driller

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
BLEW WELL WITH AIR FOR <u>1 1/2</u> hours			
TO CLEAN & DEVELOP.			

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

Signed Roger M. Thrall  
 Roger M. Thrall Contractor  
 Date 2-14-84