



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. **3281**

PRINT OR TYPE ONLY

1. OWNER Charles H. Cecchini ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Rt. 2 Box 19 _____
Round Mt., Nevada 89045 _____
 2. LOCATION $\frac{1}{4}$ W. $\frac{1}{4}$ Sec. 33 T. 11N N/S R. 43 E. Nye County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil brown		0	3	3
Clay brown		3	15	12
Gravel brown		15	20	5
Gravelly-clay brown		20	35	15
Gravel brown	W.B.	35	60	25
Gravelly-clay brown		60	95	35
Gravel brown	W.B.	95	106	11
Sandy-clay brown		106	118	12
Sand & gravel brown	W.B.	118	130	12

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 126 feet
 Casing record 126 ft. six inch casing
 Weight per foot 14 Thickness 188

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>126</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Torch
 Size perforation 95xxxxko 5 by 1/8
 From 95 feet to 126 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level +1 feet below land surface
 Flow 5 G.P.M. 1 P.S.I.
 Water temperature 54° F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name T & R WELL DRILLING Contractor
 Address 9015 S. Grassvalley Rd. Winnemucca, Nv. Contractor
 Nevada contractor's license number ~~XXXX~~ 017721
 Nevada contractor's drillers number 1190
 Nevada driller's license number 1187 Actual Driller
 Signed Thomas D. Stiles Contractor
 Date May 25, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST
 G.P.M. 30 Draw down 50 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours