WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 25524
Permit No. DOMESTIC
Basin Lemmon V. (EAST) 92(B)

I

NOTICE OF INTENT NO. 3712

1. OWNER: CRICK DEVELOPMENT
MAILING ADDRESS: P.O. Box 5267, Reno, NV 89503
ADDRESS AT WELL LOCATION: 11660 Deodar, Reno, NV 89506

2. LOCATION: SW ¼ SW ¼ Sec. 15 T. 21N N/S R. 19 E Washoe County
PERMIT NO. (Issued by Water Resources) | Parcel No. | Lemmon Valley (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown sandy clay		2	53	51
Soft zone		53	54	1
Brown sandy clay		54	60	6
Soft zone		60	62	2
Brown sandy clay		62	65	3
Softer brown clay		65	76	11
Brown clay		76	88	12
Soft zone NO H20		88	91	3
Brown clay		91	98	7
Soft zone	x	98	128	30
Brown clay		128	130	2

Date started 6-23-84, 19
Date completed 6-23-84, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 10 x 6 inches Total depth 130 feet
Casing record 130
Weight per foot ____ Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 130 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2½ x 6 around
From 92 feet to 122 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 65 feet below land surface
Flow 12 G.P.M. ____ P.S.I.
Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number 14043
Nevada contractor's drillers number 908
Nevada driller's license number 923 (Actual Driller)
Signed [signature] (Contractor)
Date June 29, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434