

OFFICE USE ONLY
 Log No. 25611
 Permit No. NO PERMIT
 Basin HONEY LAKE V.



WELL DRILLERS REPORT

Please complete this form in its entirety

CARD FILED LATE (27 JUL 84)
 NOTICE OF INTENT NO. 0060

PRINT OR TYPE ONLY

1. OWNER Fish Springs Ranch ADDRESS AT WELL LOCATION Plannigan Star Route
 MAILING ADDRESS P.O. Box 44
Reno, CA. 89504

2. LOCATION NE 1/4 NE 31 T. 26N N/S R. 19E E Washoe County
 PERMIT NO. 2166 County Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
top soil		0	6	
sand, coarse		6	8	
gravel & sand		8	15	
white sand, coarse		15	28	
sand & gravel		28	43	
tan clay, soft		43	45	
boulders		45	54	
clay & sand layers		54	60	
clay & gravel		60	70	
clay & sand		70	75	
gravel		75	80	
sand, some coarse		80	83	
boulders				
sand & gravel, cemented		83	95	
lava, Bk hard rock		95	123	
sand & gravel		123	125	
lava rock, Brn hard		125	163	
lava rock, reddish Brn		163	213	
lava rock, reddish brn		213	233	
& softer layers				
lava rock, hard, Bk		233	278	
lava rock, hard, Bk		278	303	
softer layers				
lava rock, hard & softer		303	423	
layers, red black				
lava rock, hard, Bk		423	428	
lava rock, softer		428	497	
reddish brown				

8. WELL CONSTRUCTION
 Diameter hole 26" inches Total depth 497 feet
 Casing record 16"x.250 to 235', 12 3/4".250, 497'
 Weight per foot 16"42.07, 33.38 Thickness .250 feet

Diameter	From	To
<u>16"</u> inches	<u>±1</u> feet	<u>95'</u> feet
<u>12 3/4"</u> inches	<u>492'</u> feet	<u>497'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 497' feet to 50' feet

Sawed Slots
 Perforations: 12 3/4"x.250 24 rowsx3/16"
 Type perforation 16"x.250x33x3/16"
 Size perforation 3/16x3
 From 95' feet to 235' feet
 From 235' feet to 492' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started June 29, 1984
 Date completed July 27, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Contact <u>William E. Nork</u>			

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL
 Static water level 30' feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Waldrop Drilling & Pump Co., Inc. Contractor
 Address 702-635 Johnstonville Rd
Susanville, CA. Contractor 96130
 Nevada contractor's license number Applied for
 Nevada contractor's drillers number _____
 Nevada driller's license number 1328
 Actual Driller Thomas E. Waldrop
 Signed _____ Contractor
 Date 8/6/84