

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 5210

PRINT OR TYPE ONLY

1. OWNER Nolan Little ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 SW 1/4 Sec. 19 T. 21N N/S R. 21 E Washoe County
 PERMIT NO. 2617 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay & bolders		0	4	
sand		4	14	
decomposed granite		14	180	
lava rock		180	190	
decomposed grainte		190	405	
water strata		300	320	
		375	380	

8. WELL CONSTRUCTION
 Diameter hole 8 1/2 inches Total depth 405 feet
 Casing record 6 inches
 Weight per foot _____ Thickness .188

Diameter	From	To
<u>6</u> inches	<u>-1</u> feet	<u>405</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type grout
 Depth of seal 60 feet
 Gravel packed: Yes No
 Gravel packed from 60 feet to 405 feet
 Perforations:
 Type perforation Mill slot
 Size perforation 1/8 X 3"
 From 280 feet to 320 feet
 From 360 feet to 380 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 260 feet below land surface
 Flow none G.P.M. _____ P.S.I. _____
 Water temperature cool °F. Quality good

Date started 2-4, 1986
 Date completed 2-12, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Pump & Drilling Contractor
 Address 4639 Highway 50 East Carson City Contractor
 Nevada contractor's license number 012236-B
 Nevada contractor's drillers number 1418
 Nevada driller's license number 1418
 Signed Curtis Bledsoe Actual Driller
 Contractor
 Date _____

8. PUMP TEST
 G.P.M. 10 Draw down 400 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours