

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 4625

1. OWNER Richard C. Schoening ADDRESS AT WELL LOCATION 10585 Trailmaster
 MAILING ADDRESS 10615 Plata Mesa Reno, Nv 89506
 2. LOCATION SW 1/4 SE 1/4 Sec 25 T 21 N/S R. 18 E Washoe County
 PERMIT NO. 86-161-05 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|------|-----|------------|
| Overburden | | 0 | 2 | 2 |
| Brown clay-hard | | 2 | 41 | 39 |
| Multi-colored sands with clay layers of brown | | 41 | 114 | 73 |
| Blue clay | | 114 | 115 | 1 |
| T. D. 115 | | | | |

8. WELL CONSTRUCTION
 Diameter hole 10" inches Total depth 115 feet
 Casing record 6" inches
 Weight per foot 10.78 Thickness .156
6 5/8 inches Diameter + 18" From 115 To feet
 Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 115 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 95 feet to 115 feet

9. WATER LEVEL
 Static water level 36 feet below land surface
 Flow 12 G.P.M. P.S.I.
 Water temperature 60.0 °F. Quality good

Date started 10/22, 1984
 Date completed 10/23, 1984

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|--|--------|-----------|------------------|
| Blew well with air to clean and develop. | | | |
| set test pump - pumped 12 GPM with pumping level at 86'. | | | |

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc. Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132 Actual Driller
 Signed Roger M. Thrall Contractor
 Date 10/28/84

BAILER TEST

| G.P.M. | Draw down | feet | hours |
|--------|-----------|------|-------|
| | | | |
| | | | |
| | | | |