

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6046

1. OWNER Doug Bailey
 MAILING ADDRESS 2575 Sagittarius
Reno, Nv 89509
 ADDRESS AT WELL LOCATION _____

 2. LOCATION NE $\frac{1}{4}$ SW $\frac{1}{4}$ Sec. 32 T. 17 N/S R. 20 E
Washoe County
 PERMIT NO. 50-394-09 Issued by Water Resources Parcel No. _____
New Washoe City Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loose sand		0	60	60
D.G.		60	131	71
Slightly D.G.		131	244	113
Clay - white & bluish		240	251	11
D.G.		251	258	7
T.D. 258'				
<i>Plugged by well log 118539</i>				
<i>Replaced by well log 118538</i>				

8. 10" - 55' WELL CONSTRUCTION
 Diameter hole 8" inches Total depth 258 feet
 Casing record 6 5/8 and 5 9/16
 Weight per foot 12.92 & 7.92 Thickness 188 & 134

Diameter	From	To
<u>6 5/8</u> inches	<u>11</u> feet	<u>234</u> feet
<u>5 9/16</u> inches	<u>216</u> feet	<u>258</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type grout 2 1/2 yds.
 Depth of seal 55' feet
 Gravel packed: Yes No
 Gravel packed from 55 feet to 234 feet
 Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 214 feet to 234 feet
 From 237 feet to 258 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 120 feet below land surface
 Flow 9 G.P.M. _____ P.S.I.
 Water temperature cool F. Quality clear

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc. Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132 Actual Driller
 Signed Roger M. Thrall Contractor
 Date Roger M. Thrall 3/11/86

Date started 3/6/86, 19____
 Date completed 3/11/86, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew with air for 2 1/2 hours to clean and develop.</u>			

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours