

**WELL DRILLERS REPORT**

NOTICE OF INTENT NO. 5660

PRINT OR TYPE ONLY

Please complete this form in its entirety

1. OWNER Mishler and Bjerke Construction ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1360 Manzanita 610 Oregon Blvd  
Reno, Nv 89509 Lemmon Valley

2. LOCATION NE  $\frac{1}{4}$  NW  $\frac{1}{4}$  Sec. 15 T. 21 N/S R. 19 E. Washoe County  
 PERMIT NO. 80-403-09 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D. G.		0	30	30
D. G. Salt & pepper		30	120	90
Firm D.G. salt & pepper		120	150	30
Very hard salt & pepper		150	160	10
D. G. Salt and pepper		160	210	50
white with brown and yellow D.G.		210	220	10
D. G. green & brown	X	220	298	78
D. G. green & brown water at 260'				
T.D. 298'				

8. 10" for 55' WELL CONSTRUCTION  
 Diameter hole 8" inches Total depth 298 feet  
 Casing record 6 5/8  
 Weight per foot 10.78 & 17.02 Thickness .156 & .250

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>298</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 298 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3 X .250  
 From 278 feet to 298 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 4/18/85, 19\_\_\_\_  
 Date completed 4/19/85, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air for 1 hour to clean and develop.			
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL  
 Static water level 210 feet below land surface  
 Flow 15+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool ° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service, Inc.  
 Contractor  
 Address 2255 Glendale Ave. Sparks, Nv 89431  
 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1439  
 Actual Driller  
 Signed Roger M. Thrall  
 Roger M. Thrall Contractor  
 Date 4/22/85

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____