

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4581

1. OWNER Chuck Keebaugh (Cont.) ADDRESS AT WELL LOCATION 1168 Carry Creek Crt.
 MAILING ADDRESS P.O. Box 192 Minden, Nv.
Markleeville, Calif.
 2. LOCATION 10 T. 12 N/S R. 20 E Douglas County
 PERMIT NO. _____ Subdivision Name unknown
 Issued by Water Resources Parcel No. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Dg sand & clay		0	9	
Large Boulders		9	15	
Sand & Clay		15	69	
Large Boulder		69	74	
Sand & Clay	x	74	85	
Course Dg Gravel	xx	85	101	
sand & clay	xx	101	112	
Sand & Gravel	xx	112	117	

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 117 feet
 Casing record _____
 Weight per foot _____ Thickness 188

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>117</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory Perf.
 Size perforation 3x5/32
 From 93 feet to 113 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Flow _____ G.P.M. +15 P.S.I.
 Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kawchack Drilling Inc. Contractor
 Address 1373 Judy St., Minden, NV. 89423 Contractor
 Nevada contractor's license number 021268
 Nevada contractor's drillers number 1380
 Nevada driller's license number 1380
 Actual Driller

Date started May 31 1985
 Date completed June 7 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. +15 Draw down 0 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed Eddy A. Kawchack Contractor
 Date 6/10/85