

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4585

OWNER Chuck Bowers ADDRESS AT WELL LOCATION 2335 KINCADE  
 MAILING ADDRESS 1667 Tony Ct. MINDEN, NV 89423 MINDEN NV.  
 2. LOCATION 1/4 Sec. 2 T. 13 N/S R. 20 E Douglas County  
 PERMIT NO. 23-100-04 Johnson Lane Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0	2	
CLAY & SAND		2	57	
CLAY, SAND, GRAVEL		57	70	
CLAY & SAND		70	110	
CLAY, SAND, GRAVEL		110	120	
CLAY & SAND	X	120	180	
GRAVEL	X	180	198	

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 198 feet  
 Casing record 8  
 Weight per foot \_\_\_\_\_ Thickness 188  

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>60</u> feet
<u>8</u> inches	<u>60</u> feet	<u>198</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation factory  
 Size perforation 3x3/32  
 From 178 feet to 198 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 140 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kauchack Drilling Inc. Contractor  
 Address 1373 Judy St. Minden, NV 89423 Contractor  
 Nevada contractor's license number C21268  
 Nevada contractor's drillers number 1380  
 Nevada driller's license number 1443 Actual Driller  
 Signed Eddy Kauchack Contractor  
 Date 3/29/85

Date started 3-18 1985  
 Date completed 3-29 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. +10 Draw down 5 feet 1 1/2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours