

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5063

1. OWNER Nick Johnson ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 32 Panavista same
Yerrington, NV 89447
 2. LOCATION NW 1/4 NW 1/4 Sec. 13 T. 12 N/S R. 25 E Lyon County
 PERMIT NO. _____ Lot # 2 Unit # 1 Subdivision Name _____
Issued by Water Resources Parcel No.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>1 1/2 minus gravel</u>		<u>120</u>	<u>125</u>	<u>5</u>
<u>gray clay & gravel</u>		<u>125</u>	<u>200</u>	<u>75</u>
<u>cementet silicified siltstone</u>		<u>200</u>	<u>220</u>	<u>20</u>
<u>black cemented sands & gravels</u>	<u>x308</u>	<u>220</u>	<u>252</u>	<u>32</u>
<u>cemented sands & gravels</u>	<u>60spm</u>	<u>252</u>	<u>270</u>	<u>18</u>

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 270 feet
 Casing record _____
 Weight per foot 8 Thickness 5" = 134 wall
4 1/2" = 156 wall

Diameter	From	To
<u>5</u> inches	<u>60</u> feet	<u>212</u> feet
<u>4 1/2</u> inches	<u>207</u> feet	<u>270</u> feet

Surface seal: Yes No Type DNA
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Mill slot
 Size perforation 1/8"
 From 5" feet to 186-207 feet
 From 4 1/2" feet to 247-267 feet

9. WATER LEVEL
 Static water level 56 feet below land surface
 Flow 55 G.P.M. air test P.S.I.
 Water temperature cold F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Pump & Drilling Contractor
 Address 4639 Highway 50 East Carson City Contractor
 Nevada contractor's license number 012236-B
 Nevada contractor's drillers number 1393
 Nevada driller's license number 1471 Actual Driller

Signed Curtis Blubbworth Contractor
 Date 3-24-86

Date started March 17, 1986
 Date completed March 20, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours