WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 26182
Permit No.
Basin 162

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

In Book

NOTICE OF INTENT NO. 2037

1. OWNER IRENE WILSON
MAILING ADDRESS BOX 80324
LAS VEGAS, NEV.

ADDRESS AT WELL LOCATION BARNEY + AMBLER WAY
PAHRUMP

2. LOCATION N.W. ¼ S.W. ¼ Sec. 10 T. 19 S R. 53 E NYE County
PERMIT NO. ____ (Issued by Water Resources) | LOT 248 (Parcel No.) | VALLEY VIEW ESTATES (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	5	5
HARD BROWN CLAY		5	10	5
SOFT WHITE CALECHE		10	16	6
HARD BROWN CALECHE		16	19	3
SOFT WHITE CALECHE		19	33	14
BROWN CALECHE		33	57	24
HARD BROWN CALECHE		57	61	4
SANDY BROWN CLAY		61	81	20
WHITE CALECHE		81	85	4
HARD BROWN CALECHE		85	96	11
BROWN CLAY		96	114	18
HARD BROWN CALECHE		114	127	13
W/LAYERS WHITE CALECHE				
BROWN CLAY		127	140	13

RECEIVED
JUN 25 1985
Div. of Water Resources
Branch Office • Las Vegas, NV

Date started 6-12, 1985
Date completed 6-14, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 9 inches Total depth 140 feet
Casing record 140' - 8 5/8" O.D.
Weight per foot ____ Thickness .156

Diameter	From	To
12 inches	0 feet	50 feet
9 inches	50 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation TORCH CUT
Size perforation 1/4" X 10"
From 70 feet to 140 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 45 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature ____ ° F. Quality ____

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RON FLOYD PUMP + DRILLING (Contractor)
Address P.O. BOX 157 PAHRUMP, NEV. (Contractor)
Nevada contractor's license number 7479-A
Nevada contractor's drillers number 1424
Nevada driller's license number 1427-STAN HARBIN (Actual Driller)
Signed [signature] (Contractor)
Date 6-14-85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434