



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO 2168

PRINT OR TYPE ONLY

1. OWNER Willard Henry ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 D6 1/4 Sec 29 T. 21 S. N/S R 54 E Nye County
 PERMIT NO. _____
 Issued by Water Resources Parcel No. Lot 16 Coy Hollow Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	6	6
Hard Clechre		6	14	8
Cemented		14		
Gravel			80	66
Clechre	X	80	88	8
Sandy Clay		88	108	20
Grey Sand Stone		108	138	30
Course Gravel		138	158	20
Clay		158	160	2

8. WELL CONSTRUCTION
 Diameter hole 12 1/4 inches Total depth 160 feet
 Casing record 8 3/8 X 160
 Weight per foot 14.11 Thickness 156
 Diameter From To
8 3/8 inches 0 feet 160 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 130 feet to 160 feet
 Perforations:
 Type perforation Torch
 Size perforation 4 1/2 X 6" 2 Rows
 From 130 feet to 160 feet
 From _____ feet to _____ feet

RECEIVED
 NOV 26 1985
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 8-22, 1985
 Date completed 8-22, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 50 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Custom Drilling, Inc Contractor
 Address 4425 Stacey Ave Contractor
 Nevada contractor's license number 19219
 Nevada contractor's drillers number 1081
 Nevada driller's license number 1081
 Signed C. B. Capshaw Actual Driller
 Contractor
 Date 10-10-85

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours