

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6647

1. OWNER JULIUS BUKNOWSKI ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Box 718
CARSON CITY NEV 89301
 2. LOCATION SE 1/4 SW 1/4 Sec 20 T 16 N 4 R 21 E 42N County _____
 PERMIT NO. 478625 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand Gravel Clay		0	60	60
Sand Water	60	60	65	5
Rock		65	67	2
Sandy Clay Water	67	67	75	8
Clay Gravel		75	80	5
Rock Clay Sand		80	90	10
Gravel Sand Water	90	90	100	10
Gravel Clay		100	110	10
Gravel Sand Water	110	110	140	30
Hard Rock		140	148	8

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 148 feet
 Casing record Blank to 88
 Weight per foot 16.94 Thickness .188

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>50</u> feet
<u>10</u> inches	<u>50</u> feet	<u>140</u> feet
<u>8</u> inches	<u>140</u> feet	<u>148</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 140 feet
 Perforations:
 Type perforation Machine
 Size perforation 3/32
 From 88 feet to 148 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 19 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ace Pump Sales Ser. Contractor
 Address 5551 Hwy, 50 East No. 5 Carson Contractor
 Nevada contractor's license number 15489
 Nevada contractor's drillers number 281
 Nevada driller's license number 561 Actual Driller
 Signed James W. Thompson Contractor
 Date 6-2-86

Date started 4-16, 1986
 Date completed 4-30, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 50 Draw down 88 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours