WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 27362
Permit No.
Basin 8-105 Carson

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 6916

1. OWNER Peter Pearson
MAILING ADDRESS 875 Palisade Circle
Gardnerville, Nevada

ADDRESS AT WELL LOCATION None Assigned
Blk K

2. LOCATION NE ¼ SW ¼ Sec. 17 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Sierra Vista Ranch Estates Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Gravel	✓	0	78	78'
Gravel w/Good	✓	78	103	25'
Water Sand +				
Gravel				

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 103' feet
Casing record 6 5/8" O.D. .188
Weight per foot ____ Thickness .188

Diameter	From	To
6 5/8" inches	0 feet	80' feet
6 5/8 inches	100' feet	103' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 51' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 51' feet to 103' feet

Perforations:
Type perforation 3/32 X 3½ Millshot
Size perforation
From 80' feet to 100' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 9' feet below land surface
Flow ____ G.P.M. 35+ P.S.I.
Water temperature Cool F. Quality Good

Date started 5-28, 1986
Date completed 5-30, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with 450CFM			
250 PSI air from 65'			
Well making in excess of			
35GPM			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AAA Pump Co. (Contractor)
Address P.O. Box 3432 Carson City NV. (Contractor)
Nevada contractor's license number 23295
Nevada contractor's drillers number 1472
Nevada driller's license number 1472 (Actual Driller)
Signed Clinton R. Butts (Contractor)
Date 6-4-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434