

OFFICE USE ONLY
 Log No. 27377
 Permit No. _____
 Basin 8-103 Day Valley

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 6917

1. OWNER Richard Baker ADDRESS AT WELL LOCATION Benette & Martin Dr
 MAILING ADDRESS Mound House Area

2. LOCATION S 1/4 SE 1/4 Sec 29 T 16 N R 21 E Lyon County
 PERMIT NO. Lot 1 Blk 5 Subdivision Name Green View Estates

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand, Cuttings</u>	<input checked="" type="checkbox"/>	<u>78</u>	<u>80</u>	<u>2</u>
<u>Pop Gravel, cemented w/ clay</u>		<u>80</u>	<u>87</u>	<u>7</u>
<u>Gravel, sand, no fine grain sand carrying water</u>	<input checked="" type="checkbox"/>	<u>87</u>	<u>110</u>	<u>23</u>

Note: old hole drilled by house & sons in 1977
 No indication of surface seal around 8 3/8" casing

8. WELL CONSTRUCTION
 Diameter hole 7 7/8 inches Total depth 110 feet
 Casing record 6 3/8" DD 156
 Weight per foot 11.76 Thickness 156

Diameter	From	To
<u>6 3/8</u> inches	<u>80</u> feet	<u>110</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type _____
 Depth of seal unknown feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Mill Slot
 Size perforation 3/32 x 3 1/2
 From 90 feet to 110 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 3.4 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name PAT Pump Co.
 Address P.O. Box 3432 Carson City, NV
 Nevada contractor's license number 23295
 Nevada contractor's drillers number _____
 Nevada driller's license number 1450 Actual Driller
 Signed Alvin Selby Contractor
 Date 6-6-86

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blow well for 1 hour to develop</u>			
<u>Well making 20-22 GPM</u>			

BAILER TEST

G.P.M.	Draw down	hours
_____	_____ feet	_____ hours
_____	_____ feet	_____ hours
_____	_____ feet	_____ hours