

OFFICE USE ONLY
 Log No. 27383
 Permit No. 14929
 Basin 10-162 Pahump

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2133

1. OWNER RON FLOYD ADDRESS AT WELL LOCATION S.W. CORNER DAVID + IRENE - PAHRUMP
 MAILING ADDRESS Box 157 PAHRUMP, NEV.

2. LOCATION N.E. 1/4 NW 1/4 Sec 8 T. 20 N/S R. 53 E NYE County
 PERMIT NO. 14929 NC Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation
 Municipal Industrial

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>EXISTING 12 INCH WELL</u>				
<u>320 FT. DEEP, FILLED INTO</u>				
<u>185 FT.</u>				
125 FT.				
<u>BRIDGED-BR. CLAY</u>		<u>185</u>	<u>190</u>	<u>5</u>
<u>OPEN</u>		<u>190</u>	<u>201</u>	<u>11</u>
<u>BRIDGED-BR. CLAY</u>		<u>201</u>	<u>204</u>	<u>3</u>
<u>OPEN</u>		<u>204</u>	<u>219</u>	<u>15</u>
<u>FILL-BR. CLAY-SOLID</u>		<u>219</u>	<u>320</u>	<u>101</u>
<u>BROWN CLAY</u>		<u>320</u>	<u>337</u>	<u>17</u>
<u>INSTALLED 10 3/4" O.D.</u>				
<u>LINER FROM 170 FT. TO</u>				
<u>337 FT.</u>				

8. WELL CONSTRUCTION
 Diameter hole 12 inches Total depth 337 feet
 Casing record 167 FT. OF 10 3/4 O.D.
 Weight per foot _____ Thickness .188

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>180</u> feet
<u>10 3/4</u> inches	<u>170</u> feet	<u>337</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type _____
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation TORCH CUT
 Size perforation 3/8" X 10"
 From 170 feet to 337 feet
 From _____ feet to _____ feet

Date started 5-21 1986
 Date completed 5-23 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL
 Static water level 30 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name RON FLOYD PUMP & DRILLING Contractor
 Address Box 157 PAHRUMP, NEV. Contractor
 Nevada contractor's license number 7479-A
 Nevada contractor's drillers number 1424
 Nevada driller's license number 1427 - STAN HARDIN Actual Driller
 Signed Ron Floyd Contractor
 Date 5-29-86