

WELL DRILLERS REPORT

NOTICE OF INTENT NO. 7035

PRINT OR TYPE ONLY

Please complete this form in its entirety

1. OWNER Richard Swartzendruber ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 325 Lancaster 777 N. McCarran Blvd.
Reno, Nv 89506

2. LOCATION SW ¼ SW ¼ Sec. 34 T. 20 N/S R. 19 E Washoe County
 PERMIT NO. 02-020-05
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard Pan		0	8	8
Yellow clay & rock		8	110	102
Fractured rock brown and black		110	116	6
Brown clay streaks with greenish black rock -hard-fractured		116	156	40
T.D. 156				

8.10"-55" WELL CONSTRUCTION
 Diameter hole 8½ inches Total depth 156 feet
 Casing record 6 5/8
 Weight per foot 10.78+ Thickness .156+

Diameter	From	To
<u>6 5/8</u> inches	<u>3</u> feet	<u>156</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 156 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 135 feet to 156 feet
 From _____ feet to _____ feet

Date started 6/9/86, 19_____
 Date completed 6/10/86, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

9. WATER LEVEL
 Static water level 70 feet below land surface
 Flow 25 G.P.M. P.S.I.
 Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
 Address 2255 Glendale Ave. Sparks, Nv 89431
 Contractor 15291
 Nevada contractor's license number _____
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
 Actual Driller

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed Roger M. Thrall Contractor
 Date 6/10/86