

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7482

1. OWNER Dave Wendland ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P. O. Box 452 2155 Piute Creek Rd
Sparks, Nv 89431

2. LOCATION SE 1/4 Sec. 17 T. 22 N/S R. 22 E. Washoe County
 PERMIT NO. 77-310-16 - Palomino Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|------|-----|------------|
| loose volcanic rock & sand | | 0 | 8 | 8 |
| sand layers & volcanic rock - green & yellow chips | X | 8 | 35 | 27 |
| Loose volcanic rock and volcanic sands | | 35 | 45 | 10 |
| hard volcanic rock red brown -green & yellow chips with some quartz | | 45 | 120 | 75 |
| T.D. 120 | | | | |

8. 10"-50' WELL CONSTRUCTION

Diameter hole 8 1/2 inches Total depth 120 feet
 Casing record 6 5/8"
 Weight per foot 10.78 - 12.92 Thickness .156 & .188

| Diameter | From | To |
|-------------|-----------|-----------|
|inches |feet |feet |

Surface seal: Yes No Type neat slurry
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 120 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 120 feet to 100 feet
 Fromfeet tofeet
 Fromfeet tofeet
 Fromfeet tofeet
 Fromfeet tofeet

9. WATER LEVEL

Static water level 20 feet below land surface
 Flow 24 G.P.M. P.S.I.
 Water temperature cool °F. Quality slight milk

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, INC.
 Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
 Actual Driller

Date started 8/26/86, 19____
 Date completed 8/27/86, 19____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|------------------------------------|--------|-----------|------------------|
| Blew well with air for and develop | | 2 hours | to clean |
| needs to be pumped with | pump | | |

BAILER TEST

G.P.M. Draw down _____ feet _____ hours
 G.P.M. Draw down _____ feet _____ hours
 G.P.M. Draw down _____ feet _____ hours

Signed Roger W. Thrall
 Roger W. Thrall Contractor
 Date August 29, 1986