



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8087

1. OWNER RON VUCOVICH ADDRESS AT WELL LOCATION 645 Idaho Street
MAILING ADDRESS 7410 Estes Reno, Nevada 89506
2. LOCATION SE 1/4 NW 1/4 Sec. 15 T. 21N N/S R. 19 E Washoe County
PERMIT NO. 80-384-16 Lemmon Valley
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown sandy clay		1	5	4
Green sand		5	6	1
Brown sandy clay		6	21	15
Granite boulder		21	22	1
Brown sandy clay		22	70	48
Brown soft sand		70	78	8
Brown sandy clay		78	141	63
Soft zone		141	144	3
Brown sandy clay		144	180	36
Weathered granite		180	186	6
Gray granite		186	205	19
Soft fracture granite (NO WATER)		205	207	2
Gray granite		207	231	24
Soft fracture granite		231	236	5
Gray granite		236	240	4
Soft fracture granite (approximate 7.5GPM)	X	240	273	33
Gray granite		273	283	10
Fracture	X	283	284	1
Gray granite		284	303	19

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 303 feet
6 inches
5 inches
Casing record 303 ft.
Weight per foot _____ Thickness .156/.134

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>200</u> feet
<u>5</u> inches	<u>193</u> feet	<u>303</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type ceement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from _____ feet to _____ feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From _____ feet to _____ feet
From 233 feet to 263 feet
From 283 feet to 293 feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Date started 10-7-86, 19____
Date completed 10-8-86, 19____

9. WATER LEVEL
Static water level 126 feet below land surface
Flow 15 G.P.M. _____ P.S.I.
Water temperature cold °F Quality clear

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. Contractor
Address P.O. Box 12370, Reno, NV 89510 Contractor
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Wayne Drilling, Inc.
By driller performing actual drilling on site or contractor
Date October 9, 1986

BAILER TEST
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours