

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 7397

1. OWNER Roy and Robin Wright ADDRESS AT WELL LOCATION 2355 Cartwright  
 MAILING ADDRESS P. O. Box 344  
Virginia City, Nv 89440

2. LOCATION SW 1/4 Sec 32 T. 18 N/S R. 21 E. Storey County  
 PERMIT NO. 003-014-33 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name Virginia City Highlands

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
purple and green rock		0	30	30
green and white rock with little bits of purple rock		30	40	10
Purple - white graphite hard		40	53	13
Dark green and brown hard rock		53	72	19
First H2O	97			
Blue Green and white decomposed granite		72	119	47
T. D. 119				

8.10" - 50' WELL CONSTRUCTION  
 Diameter hole 8 1/4 inches Total depth 119 feet  
 Casing record 6 5/8" .156 .188  
 Weight per foot 10.70 & 12.72 Thickness .156 & .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>119</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
 Depth of seal 52 feet  
 Gravel packed: Yes  No   
 Gravel packed from 52 feet to 119 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 99 feet to 119 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started Oct 24, 1986 19\_\_\_\_  
 Date completed Oct. 27, 1986 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL  
 Static water level 39 feet below land surface  
 Flow 25+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool ° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service, Inc.  
 Contractor  
 Address 2255 Glendale Ave. Sparks, Nv 89431  
 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132  
 Actual Driller  
 Signed Roger M. Thrall Contractor  
 Date 11/3/86