

**WELL DRILLER'S REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 8216

1. OWNER Christopher Critor ADDRESS AT WELL LOCATION 445 Puma  
 MAILING ADDRESS 445 Puma  
Carson City, Nv 89701

2. LOCATION SW 1/4 Sec. 31 T. 17 N/S R. 20 E. Washoe County  
 PERMIT NO. 50-403-20 - New Washoe City  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Mud <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown and white sand with some red clay		0	12	12
Course brown & white sand		12	32	20
Black silt with fine white sand		32	57	25
green clay with traces of sand		57	71	14
green and white coarse sand		71	108	37
T.D. 112'				
There is a 10' blank on the bottom of the screen.				

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 112 feet

Casing record 6 5/8 inches Thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 2</u> feet	<u>112</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type slurry [neat cement]  
 Depth of seal 55 feet  
 Gravel packed: Yes  No   
 Gravel packed from 112 feet to 55 feet

Perforations:  
 Type perforation Johnson screen  
 Size perforation .030 slot  
 From 92 feet to 102 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 2/9/87, 1987  
 Date completed 2/10/87, 1987

9. WATER LEVEL

Static water level 6' feet below land surface  
 Flow 11 G.P.M. P.S.I.  
 Water temperature Cold °F Quality clear

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service, Inc.  
Contractor  
 Address 2255 Glendale Ave. Sparks, Nv 89431  
Contractor  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1511  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the 1511  
 Division of Water Resources, the on-site driller  
 Signed Roger M. Thrall  
By driller performing actual drilling on site or contractor  
 Date 2/11/87

BAILER TEST

G.P.M.	Draw down	feet	hours