

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 8708

PRINT OR TYPE ONLY

1. OWNER Edwina Dittman ADDRESS AT WELL LOCATION 4390 Jumbo Grade  
 MAILING ADDRESS 4245 Jumbo Grade  
Carson City, Nv 89701

2. LOCATION SE 1/4, NE 1/4 Sec 5 T. 16 N/S R. 20 E Washoe County  
 PERMIT NO. 50-433-28 Parcel No. \_\_\_\_\_ Subdivision Name New Washoe City

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Blue green & white granite hard		0	5	5
Blue green granity slightly decomposed		5	57	52
Green red & brown white & black decomposed rock		57	162	105
Purple brown yellow white black & green rock		162	190	18
Purple brown white yellow blue green decomposed rock		190	208	18
Purple & white granite slightly fractured		208	226	18
Purple light green yellow & brown decomposed granite		226	310	84
Lt. green brown yellow granite. T.D. 330		310	330	20

8. 10"-55' WELL CONSTRUCTION  
 Diameter 8 1/2 inches Total depth 322 feet  
 Casing record 6 5/8 inches  
 Weight per foot 10.78 & 12.92 Thickness .156 & .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 1 1/2</u> feet	<u>322</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
 Depth of seal 53' feet  
 Gravel packed: Yes  No   
 Gravel packed from 53 feet to 322 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 302 feet to 322 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 4/24/87 19\_\_\_\_\_  
 Date completed 4/28/87 19\_\_\_\_\_  
 7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop for <u>2 1/2</u> hours.			

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL  
 Static water level 180 feet below land surface  
 Flow 30+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc.  
 Address 2255 Glendale Ave., Sparks, nv 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Roger M. Thrall 5/11/87  
 Date \_\_\_\_\_