


Log No. 28547
 Permit No. _____
 Basin B-103



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 6653

PRINT OR TYPE ONLY

1. OWNER Frederick Holser ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 1034 _____
Dayton Nv. 89403 _____
 2. LOCATION NE. 1/4 NW. 1/4 Sec 27 T 17 N/S R. 22 E Lyon County
 PERMIT NO. _____ Lot 80 #2 Pine Nut _____
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay		0	25	25
Sand Clay Gravel		25	50	25
Gravel Clay		50	80	30
Gravel Water Sand	80	80	100	20
Gravel Clay Sand		100	110	10
Gravel Water	110	110	120	10
Sand Gravel Clay		120	130	10
Gravel Water	130	130	140	10
Gravel Clay Sand		140	150	10

8. ~~XY~~ **XX** WELL CONSTRUCTION
 Diameter hole 2508 inches Total depth 150 feet
 Casing record Blank To L20
 Weight per foot L6.94 Thickness I88

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>50</u> feet
<u>10</u> inches	<u>50</u> feet	<u>147</u> feet
<u>8</u> inches	<u>147</u> feet	<u>150</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 147 feet

Perforations:
 Type perforation Machine
 Size perforation 3/32
 From 120 feet to 150 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level XX 71 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ace Pump Sales Service Contractor
 Address 5551 Hwy. 50 East #5 Contractor
 Nevada contractor's license number I5489
 Nevada contractor's drillers number 203
 Nevada driller's license number 561 Actual Driller
 Signed James W. Thompson Contractor
 Date 5-27-87

Date started 3-16, 1987.
 Date completed 3-30, 1987.

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 25 Draw down 5 feet I hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours