WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28940
Permit No.
Basin 9-1056

I

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8251

1. OWNER Steve Stringham
MAILING ADDRESS 889 Spring Valley Drive
Gardnerville, Nev.
ADDRESS AT WELL LOCATION 889 Spring Valley Drive

2. LOCATION SE ¼ SW ¼ Sec. 36 T. 11 N/S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name None

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	6	6
Cemented gravels		6	85	79
Gravel & Sand, 26 ft Water	✓	85	87	2
Cemented gravels		87	93	6
Very hard fine fractured Stone Stone		93	130	37
Fractured Stone Stone, hard Cuttings	✓	130	145	15
T.D. 145 ft				

Date started July 27, 1957
Date completed July 30, 1957

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow well to clean, developed and gravel pack			
Water Making 18 ft. Gravel pack 130'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 inches Total depth 145 feet
5 1/2 inches
inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2.5 feet	145 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 57 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 57 feet to 145 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3/4
From 130 feet to 145 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 55 feet below land surface
Flow 15-20 G.P.M. ..... P.S.I.
Water temperature 64 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Stage Co (Contractor)
Address 577 Hwy 50 E Carson City, Nev. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23095
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1477
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7/30/57

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627