WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. Z9006
Permit No. DOMESTIC
Basin WASHOE V. 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9367

1. OWNER Young Enterprises, Inc.
MAILING ADDRESS 4270 Sacramento Lane Reno, Nevada
ADDRESS AT WELL LOCATION 1915 Lakeshore Drive Carson City Nevada

2. LOCATION NW ¼ NW ¼ Sec. 31 T. 17 N/S R. 20 E. WASHOE County
PERMIT NO. WCty 3096 (Issued by Water Resources) Parcel No. NEW WASHOE CITY (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ blow sand		0	6	6
Fine sand w/ clay seams interspersed with silt	✓	6	97	91
Coarse sand with silt and layers of clay	✓	97	130	33
T.D. 130 Ft				

Date started Aug 31, 1987
Date completed Sept 2, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with fresh water to remove drill mud & gravel pack			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 1/4 inches Total depth 130 feet
..... inches
..... inches
Casing record 6 5/8
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 57 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 57 feet to 130 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 1/16" x 3 1/2"
From 102 feet to 122 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 12 feet below land surface
Flow 30 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A&H Pump Co. (Contractor)
Address 1851 Hwy 50 E Carson City, Nev. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1477
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Sept 3, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627