WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29070
Permit No.
Basin 2-104

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9375

1. OWNER Art Van Dyke
MAILING ADDRESS Carson City, Nev

ADDRESS AT WELL LOCATION Heaven Hill Way
Carson City, Nev 89701

2. LOCATION SE ¼ SE ¼ Sec. 32 T. 16 N/S R. 20 E. Carson City County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name None

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN & SAND		0	2	2
TAN TO BROWN SAND, FINE TO COURSE, COMPACT		2	8	6
MEDIUM TO HARD GRANITE, BROWN TO GREY COLOR		8	36	28
GRANITE GREY-BLUE FINE TO COURSE GRAIN, HARD TO VERY HARD, FIRST FRACTURE @ 127' NEXT FRACTURE @ 127, BOTH DRY	See Amended log #29070	36	245	195
FRACTURES WITH WATER AT 203, 217, 240-241	✓			
T.D. 245				

Date started Sept 14, 1987
Date completed Sept 18, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
GRAVEL PACKED & DEVELOPED WITH 250 PSI AIR			
12-14 GPM FROM 220'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 60' inches Total depth 245 feet
5 1/2 inches
8 inches
Casing record 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	42 feet	245 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 57 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 57 feet to 245 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3 1/2
From 220 feet to 240 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 154 feet below land surface
Flow 12-14 G.P.M. P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name D & H Pump Co (Contractor)
Address 551 Hwy 50 E C. City, Nv (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Sept 21, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627