



**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7578

1. OWNER Henry Meyers ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
Hardyville NV 89410  
 2. LOCATION E 1/2 1/4 NW 1/4 Sec 18 T 12 N/S R 26 E Douglas County \_\_\_\_\_  
 PERMIT NO. 27-020-07 Centerville Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	4	4
Sand & Gr	X	4	26	22
Clay & Sand		26	42	16
Gr & Sand	X	42	78	36
Clay		78	85	7

8. WELL CONSTRUCTION  
 Diameter hole 6 inches Total depth 85 feet  
 Casing record \_\_\_\_\_  
 Weight per foot 456 Thickness 156  
 Diameter 6 inches From 0 feet To 85 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type \_\_\_\_\_  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation 3/32 Saw cut  
 Size perforation 3/32 x 3  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 63 feet to 85 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 3' feet below land surface  
 Flow \_\_\_\_\_ G.P.M. 20 P.S.I.  
 Water temperature \_\_\_\_\_ °F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kawchack Drilling Inc. Contractor  
PO Box 536  
 Address Hardyville NV 89410 Contractor  
 Nevada contractor's license number 021268  
 Nevada contractor's drillers number 763  
 Nevada driller's license number 545 Actual Driller  
 Signed Eddy Kawchack Contractor  
 Date 9-22-87

Date started \_\_\_\_\_, 19\_\_\_\_  
 Date completed \_\_\_\_\_, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours