

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8037

1. OWNER JIM PAULLO ADDRESS AT WELL LOCATION Patrina  
 MAILING ADDRESS P.O. Box 20145 Sparks, NV  
Sun Valley, NV 89433  
 2. LOCATION NW 1/4 NW 1/4 Sec. 4 20N N/S R. 20 E Washoe County Spanish Springs  
 PERMIT NO. 83-440-46 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1/2	1/2
Brown sandy clay with gravels & boulders		1/2	32	31 1/2
Soft zone		32	34	2
Brown sandy clay with gravels		334	92	58
Soft zone		92	115	23
Brown sandy clay with gravels		115	120	5
Soft zone (NO H2O)		120	131	11
Brown sandy clay		131	160	29
Soft zone (appr. 3GPM)	X	160	171	11
Brown sandy clay with gravels		171	195	24
Soft zone		195	196	1
Soft sandy clay with gravels		196	248	52
Soft zone	X	248	257	3
Brown clay		257	261	4
Soft zone		261	269	8
Brown clay		269	275	6

8. WELL CONSTRUCTION  
 Diameter 6 inches Total depth 275 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 275' steel casing installed  
 Weight per foot \_\_\_\_\_ Thickness .156  

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>275</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 275 feet  
 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 6 around  
 From 161 feet to 171 feet  
 From 211 feet to 222 feet  
 From 242 feet to 264 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 9-15-87, 19\_\_\_\_  
 Date completed 9-16-87, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 135 feet below land surface  
 Flow 16 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370, Reno, NV 89510 Contractor  
 Nevada contractor's license number 22549 issued by the State Contractor's Board  
 Nevada contractor's driller's number 908 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on site driller 923  
 Signed Wayne Drilling, Inc.  
 By driller performing actual drilling on site or contractor  
 Date September 19, 1987