

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8958

1. OWNER Jack Waretter ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3030 Boyer Rd _____
Tullon, NV. 89406 _____
 2. LOCATION NE 1/4 NE 1/4 Sec 7 T 18 N/S R. 28 E Churchill County
 PERMIT NO. none Issued by Water Resources Parcel No. 1 Subdivision Name none

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>	<u>0</u>	<u>0</u>	<u>1</u>	<u>1</u>
<u>Clay, brown</u>	<u>0</u>	<u>1</u>	<u>38</u>	<u>37</u>
<u>Clay-Sand mixed</u>	<u>0</u>	<u>38</u>	<u>47</u>	<u>9</u>
<u>gray</u>	<u>0</u>	<u>38</u>	<u>47</u>	<u>9</u>
<u>Sand, brown</u>	<u>16</u>	<u>47</u>	<u>53</u>	<u>6</u>
<u>Med coarse</u>	<u>5'-4"</u>	<u>53</u>	<u>53 1/2</u>	<u>1/2</u>
<u>Gravel</u>				

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 53 1/2 feet

Casing record + 1 1/2' + 0 53 1/2'

Weight per foot 17.02 Thickness 1.750

Diameter	From	To
<u>6</u> inches	<u>+ 1 1/2</u> feet	<u>53 1/2</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type neat

Depth of seal 25 feet

Gravel packed: Yes No

Gravel packed from 52 1/2 feet to 53 1/2 feet

Perforations:

Type perforation Teach.

Size perforation 5/32 x 4"

From 50 1/2 feet to 53 1/2 feet

Date started 9-11- 1987
 Date completed 9-12 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3600</u>	<u>25</u>	<u>10'-48"</u>	<u>2</u>
<u>Set Pump @ 30'</u>			
<u>Don't Pump over 20 gpm.</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL

Static water level 51-4" feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature Cold °F Quality EXCELLENT

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Water Ret Well Drilling Contractor

Address P.O. Box 883 Tullon, NV. 89406 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0023978

Nevada contractor's driller's number issued by the Division of Water Resources 1475

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475

Signed Gerald H. Olson By driller performing actual drilling on site or contractor

Date 9-12-87