WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29049
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9375

1. OWNER Albert Tryon
MAILING ADDRESS 220 Magpie, Carson City, Nevada 89701
ADDRESS AT WELL LOCATION EAST WASHOE 220 Magpie Carson City, NV 89701

2. LOCATION SE ¼ SE ¼ Sec. 31 T. 17 N/S R. 20 E WASHOE County
PERMIT NO. WCty 3108 (Issued by Water Resources) 050-413-27 (Parcel No.) NEW WASHOE #5 (Subdivision Name)

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☑ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cleaned out existing well, 60-100 Ft Old Well is 100 Ft deep				
Medium to hard granite		100	210	110
Hard granite w/ small fractures, 1" to 2" w/ small amounts of water	✓	210	260	50
Note: Original well drilled about 10 years ago				

Date started 9/9/87, 1987
Date completed 9/11/87, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with air to clean open fractures			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 1/8 inches Total depth 260 feet
..... inches
..... inches
Casing record 6 5/8"
Weight per foot ..... Thickness .....

Diameter	From	To
6 5/8 inches	0 feet	100 feet
5 9/16 inches	80 feet	260 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type Unknown
Depth of seal Unknown feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 7/32 x 3 1/2
From 210 feet to 260 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 80 feet below land surface
Flow 9-10 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AEH Pump Co (Contractor)
Address 5551 Hiway 50E #3 Carson City, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23795
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Sept 11, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627