WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29052
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8956

1. OWNER MELBA FAY ALLDREDGE
MAILING ADDRESS 2425 HARRIGAN Rd. FALLON, NV. 89406
ADDRESS AT WELL LOCATION SAME AS OWNER

2. LOCATION S½ N NE ¼ Sec. 5 T. 18 N/S R. 29 E. churchill County
PERMIT NO. none (Issued by Water Resources) | Parcel No. 1 | Subdivision Name none

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [X] Irrigation [ ] Test [ ] Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL: Cable [X] Rotary [ ] Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	1	1
CLAY, GRAY		1	13	12
CLAY, BROWN		13	29	16
SAND, FINE BROWN		29	30	1
SAND & CLAY, GRAY		30	36	6
CLAY, GRAY		36	40	4
SAND & CLAY, GRAY		40	60	20
CLAY, BLACK		60	75	15
CLAY, GRAY		75	90	15
CEMENTED GRAY GRAVEL		90	95	5
CLAY, GRAY		95	96	1
SAND, COURSE BROWN 9		96	97	1

Date started 8-24-87, 19
Date completed 8-27-87, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	10	43	3
SET Pump AT 75'			
Do NOT PUMP OVER 10gpm			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 97 feet
inches
inches
Casing record +20" to 97'
Weight per foot 17.02 Thickness .250

Diameter	From	To
6 inches	+20" feet	97' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type neat
Depth of seal 25 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 96 feet to 97 feet

Perforations:
Type perforation Torch
Size perforation 5/32 x 4
From 94 feet to 97 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 9 feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality good.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water-Rite Well Drilling (Contractor)
Address P.O. Box 883 Fallon, NV. 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0023978
Nevada contractor's driller's number issued by the Division of Water Resources 1475
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475
Signed Gerald A. Allen (By driller performing actual drilling on site or contractor)
Date 8-28-87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627