AMENDED LOG

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29070
Permit No.
Basin 8-104

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9345

1. OWNER ART VAN DYKE
MAILING ADDRESS 8 MENLO CT CARSON CITY, NV
ADDRESS AT WELL LOCATION 59 Heaven Hill Way Carson City, Nevada

2. LOCATION SE ¼ SE ¼ Sec. 32 T. 16 N/S R. 20 E. Carson City County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name None

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden + Sand		0	2	2
Tan to brown Sand, fine to Course, highly Compacted		2	8	6
Medium to hard Granite, brown-Grey Color		8	36	28
Granite, Grey-blue, Fine to Course Grain, Hard to Very hard First fracture @ 127', Next fracture @ 187'. Both dry		36	205	169
Fractures with Water @ 193, 197, 201 to 203				
T.D. 205				

See original log # 29400

Date started SEPT 14, 1987
Date completed SEPT 18, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Gravel packed & developed with 250 psi air			
12-14 GPM From 180 Ft			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 10 3/4" to 6 inches Total depth 205 feet
8 1/2 inches
8 inches
Casing record 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	205 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 57 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 57 feet to 205 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 X 3 1/2"
From 180 feet to 200 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 154 feet below land surface
Flow 12-14 G.P.M. ____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name P & H Pump Co. Contractor
Address 5551 Hwy 50E #3 C. City, NV Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Newton Butts
By driller performing actual drilling on site or contractor
Date Sept 29, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627