

OFFICE USE ONLY
 Log No. 29169
 Permit No. _____
 Basin 9-107
 9477

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 9477

PRINT OR TYPE ONLY

1. OWNER Monteray Development ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 90 Associated Realty Wellington, Nev. 89444
P.O. Box 11557 Reno, NV 89510
 2. LOCATION NE 1/4 NE 1/4 Sec 32 T. 12 N. R. 23 E. Lyon County
 PERMIT NO. _____ Parcel No. Lot 19 Subdivision Name Feathill Estates
 Issued by Water Resources _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Hard granite rock</u>	<u>No</u>	<u>0</u>	<u>135</u>	<u>135</u>
<u>Some clay and gravel</u>				
<u>Clay and gravel mix and more hard granite</u>	<u>No</u>	<u>135</u>	<u>175</u>	<u>40</u>
<u>Water-bearing gravel and morde rock</u>	<u>X</u>	<u>175</u>	<u>213</u>	

8. WELL CONSTRUCTION

Diameter 8 inches Total depth 213 feet

Casing record 213

Weight per foot _____ Thickness 250

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>213</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Concrete

Depth of seal 50 feet

Gravel packed: Yes No

Gravel packed from _____ feet to _____ feet

Perforations:

Type perforation Factory saw slot

Size perforation 5/32" x 3"

From 179 feet to 205 feet

From _____ feet to _____ feet

9. WATER LEVEL

Static water level 155 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name FMDL Co, INC. Contractor

Address Box 92, Smith, Nev 89430 Contractor

Nevada contractor's license number issued by the State Contractor's Board 24149

Nevada contractor's driller's number issued by the Division of Water Resources 24149

Nevada driller's license number issued by the Division of Water Resources the on-site driller 221573

Signed Scott Chiswick
 By driller performing actual drilling on site or contractor

Date 9-23-81

Date started 9-8- 1981

Date completed 9-21- 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours
<u>20</u>	<u>30</u>	<u>3</u>	
_____	_____	_____	_____
_____	_____	_____	_____