WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29185
Permit No. 48969
Basin 10-127

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 26612

1. OWNER Capricorn Interprises
MAILING ADDRESS 304-700 West Pender St. VANCOUVER B.C. V6C 1G8
ADDRESS AT WELL LOCATION 2.5 mile East of Middlegate

2. LOCATION NW ¼ SW ¼ Sec. 34 T. 16 N/S R. 37 E Churchill County
PERMIT NO. 48969 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☑ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil & Clay		0	30	30
Clay & Caliche & Stray		30	50	20
Brown Mud Stone		50	70	20
" " "		70	90	20
Shale with some gyp		90	110	20
Grey Green Shale		110	130	20
Hard & Fractured Water		130	132	2
Broken Volcanics		132	140	8
Some Fractures		140	150	10
Very Hard White Rock		150	150	5

Date started 8-28, 1987
Date completed 9-10, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blowed	Appr.	20	g.p.m.
For	8	hrs.	

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 9 7/8 inches Total depth 150 feet
Casing record 6 5/8
Weight per foot ..... Thickness .188

Diameter	From	To
6 5/8 inches	-2 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 150 feet

Perforations:
Type perforation Factory Saw cut
Size perforation 5/8 X 3" Double Perfed
From 130 feet to 150 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 43 feet below land surface
Flow None G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jim Potter (Contractor)
Address P.O. Box 1815 Fallon, Nev. (Contractor)
Nevada contractor's license number 1348
Nevada contractor's drillers number .....
Nevada driller's license number 020161 (Actual Driller)
Signed Jim Potter (Contractor)
Date 9-12-87

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434