

OFFICE USE ONLY  
 Log No. 29197  
 Permit No. \_\_\_\_\_  
 Basin 87

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8879

1. OWNER Keith Osgood  
 MAILING ADDRESS 2500 Dickerson Rd # 31  
Reno, Nv 89503  
 ADDRESS AT WELL LOCATION Buckeye Rd  
Lot 79  
 2. LOCATION NW 1/4 SE 1/4 Sec. 31 T. 18 N/S R. 20 E. Storey County  
 PERMIT NO. 03-451-36 Virginia City Highlands Subdivision Name  
 Issued by Water Resources Parcel No.

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Volcanic rock fill		0	2	2
Reddish brown white yellow volcanic rock		2	21	19
Red clay with red & white volcanic rock		21	34	13'
Reddish brown white and yellow volcanic rock		34	168	134
Brown purple white reddish brown with some light purple clay		168	387	219
Reddish brown yellow white & brown volcanic rock		387	464	77
Blue gray & white rock with some traces of gray clay		464	915	451
Gray rock with white specs hard	980	915	1002	87
T.D. 1002				

8. 10" - 60' WELL CONSTRUCTION  
 Diameter 8 1/2 inches Total depth 1002 feet  
 Casing record 6 5/8 5" inches  
 Weight per foot 10.78 6.96 Thickness .156 .134  
 Diameter 6 5/8 inches From 882 To 1002 feet  
 Surface seal: Yes  No  Type grout  
 Depth of seal 55 feet  
 Gravel packed: Yes  No  55 feet to 882 feet  
 Perforations: Type Factory  
 Size perforation 3/32 X 3  
 From 862 feet to 882 feet  
 From 982 feet to 1002 feet

Date started 10/6/87 19  
 Date completed 10/16/87 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop for <u>1 1/4</u> hours.			

BAILER TEST

G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours

9. WATER LEVEL  
 Static water level 10 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc.  
 Contractor  
 Address 625 Spice Islands Dr. Suite L Sparks, NV  
89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the 1511  
 Division of Water Resources the on-site driller  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date 10/23/87