



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 6660

PRINT OR TYPE ONLY

1. OWNER James Stark ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4785 Apache Dr.
Stage Coach Nev, 89429 same
 2. LOCATION SW 1/4 SW 1/4 Sec. 35 T. 18 N/S R. 23 E Lyon County
 PERMIT NO. 15-081-16 Stage Coach
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand Gravel Rock		0	5	5
Sand Gravel Clay		5	20	15
Boulder		20	22	2
Gravel Clay		22	173	151
Sand Gravel Water	I73	I73	I75	2
Sand Gravel		I75	I80	5
Gravel Water	I80	I80	200	20
Sand Clay		200	205	5
Sand Gravel Water	205	205	235	30

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 235 feet
 Casing record Blank To 194
 Weight per foot 16.94 Thickness 188

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>50</u> feet
<u>10</u> inches	<u>50</u> feet	<u>230</u> feet
<u>8</u> inches	<u>230</u> feet	<u>235</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 230 feet
 Perforations:
 Type perforation Machine
 Size perforation 3/32
 From 194 feet to 235 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 158 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

Date started 8 21, 1987
 Date completed 9 11, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ace Pump Sales Ser. Contractor
 Address 5551 Hwy. 50 East #5 Contractor
 Nevada contractor's license number 15489
 Nevada contractor's drillers number 203
 Nevada driller's license number 561 Actual Driller
 Signed James W. Thompson Contractor
 Date 12 18 87

BAILER TEST
 G.P.M. 25 Draw down 20 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours