WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29283
Permit No.
Basin 102 - Churchill V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9386

1. OWNER Wayne & Kay Martin
MAILING ADDRESS Silver Springs, Nevada
ADDRESS AT WELL LOCATION 1665 Getty Way Silver Springs, Nevada

2. LOCATION NE ¼ SE ¼ Sec. 15 T. 18 N/S R. 24 E. Lyon County
PERMIT NO. ..... Issued by Water Resources | #2 Map 98606 Parcel No. | Horse Stock Canyon Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden with sand & Boulders		0	2	2
Grey-white Caliche Clay		2	83	81
Brownish Clay		83	110	27
Green-grey fine grained Hard rock		110	218	108
Brownish-black with red streaks, Lava type rock. Main water fractures at 220 & 240		218	260	42
T.D. 260 FT				

Date started Oct 23, 1987
Date completed Oct 27, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to develop and gravel pack			
35+ GPM from 220 Feet			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 260 feet
5½ inches
..... inches
Casing record 6 5/8
Weight per foot 11.7 Thickness 156

Diameter	From	To
6 5/8 inches	42 feet	260 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 260 feet to 260 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 X 3½
From 230 feet to 250 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ..... feet below land surface
Flow 35+ G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. Contractor
Address 5337 Hwy 50 E #5 Carson City, Nv Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature]
By driller performing actual drilling on site or contractor
Date Oct 27, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627