

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8959

1. OWNER Robert KRAKE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4380 JAWGHN RD. FALLON, NV. 89406 SAME AS OWNERS
 2. LOCATION NW 1/4 SE 1/4 Sec. 2 T. 19 N/S R. 29 E. Church: 11 County _____
 PERMIT NO. N.W.E. #2 Issued by Water Resources Parcel No. _____
JOHN SEEP Subdivision Name SUBDIVISION

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>OVER BURDEN</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>SAND, BROWN, FINE</u>		<u>10</u>	<u>21</u>	<u>11</u>
<u>CLAY BROWN</u>		<u>21</u>	<u>43</u>	<u>22</u>
<u>CLAY GRAY</u>		<u>43</u>	<u>68</u>	<u>25</u>
<u>CLAY, BROWN</u>		<u>68</u>	<u>84</u>	<u>16</u>
<u>SAND, BROWN FINE</u>		<u>84</u>	<u>86</u>	<u>2</u>
<u>SAND, BROWN COARSE</u>		<u>86</u>	<u>88</u>	<u>2</u>

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 88 feet
 _____ inches
 _____ inches
 Casing record + 2' to 88'
 Weight per foot _____ Thickness _____

Diameter	From	To
<u>6</u> inches	<u>+ 2'</u>	<u>88</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type NEAT
 Depth of seal 25 feet
 Gravel packed: Yes No
 Gravel packed from 87 feet to 88 feet

Perforations:
 Type perforation Teach
 Size perforation 3/2
 From 85 feet to 88 feet
 From _____ feet to _____ feet

Date started 9-29-87, 19____
 Date completed 10-2-87, 19____

9. WATER LEVEL
 Static water level 14 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality EXCELLENT

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3600</u>	<u>10</u>	<u>36</u>	<u>2 hrs</u>
<u>SET Pump @ 70'</u>			
<u>Don't let Pump OVER 10 P.M.</u>			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Water-Rite Well Drilling Contractor
 Address P.O. Box 883 Fallon, NV. 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 4485 0023978
 Nevada contractor's driller's number issued by the Division of Water Resources 1475
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1525
 Signed Sam Olson By driller performing actual drilling on site or contractor
 Date 10-2-87

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____