WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29248
Permit No.
Basin 6-84

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9570

1. OWNER MICHAEL & TOREY BRIDGES
MAILING ADDRESS P.O. Box 5998
Sparks, NV 89433

ADDRESS AT WELL LOCATION Alexander
Sparks, NV

2. LOCATION SE ¼ SE ¼ Sec. 6 T. 21N N/S R. 22 E. Washoe County
PERMIT NO. (Issued by Water Resources) 077-24-14 (Parcel No.) Palomino Valley (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil, brown clay		0	2	2
Loose graveel & sand		2	6	4
Light brown clay with volcanic rocks		6	38	32
Soft brown clay		38	42	4
Brown soft volcanic mud flow		42	71	29
Brown volcanic rock		71	96	25
Soft fracture(app.3GPM)	X	96	97	1
Brown volcanic rock		97	110	13
Fracture zone(app.2GPM)	X	110	112	2
Brown volcanic rock		112	127	15
Fracture zone(app.5GPM)	X	127	141	14
Brown to gray volcanic rock		141	150	9
Fracture zone(NO WATER)		150	154	4
Brown to gray volcanic rock		154	165	11
Fracture zone	X	165	171	6
Brown to black volcanic rock		171	182	11
Fracture zone	X	182	189	7
Brown to black volcanic rock		189	205	16

Date started 11-10-87, 19
Date completed 11-11-87, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 205 feet
inches
inches
Casing record 205' steel casing installed
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	205 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 51 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 51 feet to 205 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 86 feet below land surface
Flow 20 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date November 16, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627