WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 29280
Permit No.
Basin 6-88

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9590

1. OWNER GAYLORD ANDERSON
MAILING ADDRESS 355 Clevite Lane
Reno, NV 89511

ADDRESS AT WELL LOCATION 18111 Bain Springs Road
Reno, NV 89511

2. LOCATION NW ¼ SW ¼ Sec. 2 T. 17N N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) 050-030-12 (Parcel No.) S Steamboat Area (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown volcanic rock		2	61	59
Soft zone		61	62	1
Brown volcanic rock		62	66	4
Soft zone		66	67	1
Brown volcanic rock		67	81	14
Soft zone (app 8-10GPM)	X	81	85	4
Brown volcanic rock		85	105	20
Black volcanic rock		105	132	27
Soft zone		132	133	1
Black volcanic rock		133	136	3
Soft zone		136	137	1
Black volcanic rock		137	142	5
Gray volcanic rock		142	160	18
Soft zone (app 5 GPM)	X	160	170	10
Gray volcanic rock		170	194	24
Fracture	X	194	196	2
Gray volcanic rock		196	202	6
Fracture zone	X	202	214	12
Gray soft volcanic rock		214	225	11

Date started 10-22-87, 19
Date completed 10-23-87, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 225 feet
inches
inches
Casing record 225' steel casing installed.
Weight per foot Thickness .156

Diameter	From	To
6 5/8" inches	0 feet	225 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 51 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 51 feet to 225 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 197 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 81 feet below land surface
Flow 30+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, Nv 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date October 27, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627